

North Dakota Office of the State Fire Marshal (ND)

INCIDENT REPORT

Official Law Enforcement Report - Unauthorized Dissemination is Prohibited

Incident Type: Fire

Agency Incident ID:

NDSFM25-015

BATS ID: 1545216

Investigation Title:

HARVEY AXTMANN FIRE



Incident Date/Time/Location

Status

Investigation Closed

Jurisdiction

Primary

Start Date/Time

2/6/2025 05:13 Thursday

Address

3570 33rd Ave

City/State/Zip

Harvey, ND 58341

County

Pierce County

Investigator Information

Name

Andrew J Browne

Phone

701-720-9264

Email

abrowne@nd.gov

Title

Deputy State Fire Marshal

Property Use or Target Information

Type


Residential

Subtype

1 (Single Family) or 2 Family Dwelling

Status

Occupied And Operating



North Dakota Office of the State Fire Marshal (ND)

INCIDENT REPORT

Official Law Enforcement Report - Unauthorized Dissemination is Prohibited

Incident Type: Fire

Agency Incident ID: NDSFM25-015

BATS ID: 1545216

Investigation Title: HARVEY AXTMANN FIRE



Scene Details


Miscellaneous Information

Latitude

47.927799

Longitude

-99.875964



North Dakota Office of the State Fire Marshal (ND)

INCIDENT REPORT

Official Law Enforcement Report - Unauthorized Dissemination is Prohibited

Incident Type: Fire

Agency Incident ID: NDSFM25-015

BATS ID: 1545216

Investigation Title: HARVEY AXTMANN FIRE



Attachments

Filename	Description	Date
NDSFM25-015-Axtmann Fire.pdf		2/10/2025

No image specified



North Dakota Office of the State Fire Marshal (ND)

INCIDENT REPORT

Official Law Enforcement Report - Unauthorized Dissemination is Prohibited

Incident Type: Fire

Agency Incident ID: NDSFM25-015

BATS ID: 1545216

Investigation Title: HARVEY AXTMANN FIRE



Narrative(s)

Title

Opening Report

Author

Andrew Browne

7017209264

abrowne@nd.gov

Description

For Distribution Via Email Only: Fire Chief Ryan Schneibel, Harvey Fire Department, perfectionautobody@gondtc.com



North Dakota Office of the State Fire Marshal (ND)

INCIDENT REPORT

Official Law Enforcement Report - Unauthorized Dissemination is Prohibited

Incident Type: Fire

Agency Incident ID: NDSFM25-015

BATS ID: 1545216

Investigation Title: HARVEY AXTMANN FIRE



This section intentionally left blank

Investigator/Agent - Browne, Andrew

Date

Approving Official

Date



North Dakota State Fire Marshals Office (ND)
SUPPLEMENTAL REPORT NARRATIVE
Official Law Enforcement Report – Unauthorized Dissemination is Prohibited



Incident Type: Fire/Arson

Agency Incident ID: NDSFM25-015

BATS ID: i-1545216

Investigation Title: Harvey Axtmann Fire

Lead Fire/Explosion Origin and Cause Investigator:		
Name	Agency	Case Reference if Available
Ryan Schniebel	Harvey Fire Department	2025-1

Fatalities/Injuries:		
Name	Fatality/Injury:	Notes/Other Information:
		No injuries or fatalities report to the State Fire Marshal's Office.

Reason For Supplemental Report:
On Thursday, February 6, 2025, at approximately 6:23 am, I Deputy State Fire Marshal Andrew Browne received a telephone call from North Dakota State Radio Dispatch regarding a request to call the Harvey Fire Department Fire Chief Ryan Schniebel regarding a fire. I contacted Fire Chief Schniebel regarding the request via telephone. Fire Chief Schniebel stated that a fire occurred in a attached garage at 3570 33 rd Ave Harvey, ND. During the conversation it was agreed that I would not respond and document the fire as a Tip.

Remarks:
<p>Fire Chief Schniebel stated Harvey Fire Department was dispatched to a fire at 5:13 am on February 6, 2025, for an attached garage fire. Fire Chief Schniebel stated the fire damage was minor to the structure and contained to the garage.</p> <p>Fire Chief Schniebel stated the fire was believed to have started from portable propane heater inside the garage that came in contact with combustible material being stored nearby.</p> <p>Fire Chief Shcnielbel provided me with a copy of the Harvey Fire Department incident report and photographs. The incident report and photographs will remain with the file.</p> <p>No other assistance from the North Dakota State Fire Marshal's Office was being requested at this time.</p>